

Evidence of Performance

Air permeability, Watertightnes, Resistance to wind load



Test Report

No. 16-002206-PR02

(PB-A01-02-en-02)

Client	SCHÜCO International KG Karolinenstr. 1-15 33609 Bielefeld Germany
Product	Double slide & fold system SCHÜCO ASS 80 FD.HI 2 turn-only sash 90° at the corner
Designation	SCHÜCO ASS 80 FD.HI
Material	Aluminium profiles with thermal break
Overall dimensions (WxH)	1,425 / 1,400 mm x 3,177 mm
Closed condition	Closed, fastened and locked (in main latchbolt, deadbolt and auxiliary latchbolts)
Special features	-/-

Basis

EN 14351-1:2006+A1:2010

Test standard/s:
EN 1026:2000-06
EN 1027:2000-06
EN 12211:2000-06

Equivalent national versions (e.g. DIN EN)

Test report 16-002206-PR02
(PB-A01-02-de-02) dated
17.01.2018.

Representation



Results

Air permeability according to EN 12207:1999-11



Class 3

Watertightness according to EN 12208:1999-11



Class 6A

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C1 / B1

Instructions for use

The manufacturer is allowed to use the results obtained for preparing a Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EC. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 26 pages.

ift Rosenheim

14.02.2018

Peter Marquardt, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Component Testing

Stephan Bertagnolli, Dipl.-Ing. (FH)
Operating Testing Officer
Building Component Testing